

CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



NOTIFICATION OF TEST RESULTS

NTR/ PL2 0177

Product	Flush-type, rocker installation switches.
Tested by request of	KONTAKT-SIMON S.A. ul. Bestwińska 21 43-500 Czechowice-Dziedzice, Poland
Manufactured at (name and place)	KONTAKT-SIMON S.A. ul. Bestwińska 21 43-500 Czechowice-Dziedzice, Poland
Preliminary visit carried out by	BBJ
Rating and principal characteristics	16 AX; 250 V~; IP20
Trade mark (if any)	
Model/Type Ref.	series CLASSIC, type: MW1A/.., MW2A/.., MW5A/.., MW6A/.., MS1A/.., MD1A/.., MW1AL/.., MW2AL/.., MW5AL/.., MW6AL/.., MS1AL/.., MD1AL/.. series BASIC MODUŁ, type: BMW1A/.., BMW2A/.., BMW5A/.., BMW6A/.., BMS1A/.., BMD1A/.., BMW1AL/.., BMW2AL/.., BMW5AL/.., BMW6AL/.., BMS1AL/.., BMD1AL/.. /.. – colour code and method of packing
Additional information (if necessary)	This product is covered by a certificate of the BBJ
A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard) EN 60669-1:1999+A1:2002+A2:2008+IS1:2009	
as shown in the test reports (reference No.) LO-11.81K/E	

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates directly in the CENELEC Certification Agreement (CCA) of September 11th, 1973 as revised on March 29th, 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA.

Association of Polish Electricians
Quality Testing Office (BBJ)



Warsaw, December 10, 2011

Director

Address: ul. M. Pożaryskiego 28
04 -703 Warszawa, Poland

tel.: (+48 22) 812 35 10 fax.: (+48 22) 815 65 80
e-mail: bbj@bbj.pl www.bbj.pl